



# Imagine Hope PCS [Tolson] - Lead in Water Test Results



## FY21 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Imagine Hope PCS [Tolson]	WS-061-001	Food Prep Sink	1	In lunch prep			WF-022021-061001-03	5/12/2021	FT-FY21-022021-061001-A	<1	FT-FY21-022021-061001-B	<1
Imagine Hope PCS [Tolson]	WS-061-002	Combo Faucet	1	In classroom 111		Left	WF-022021-061002-03	5/12/2021	FT-FY21-022021-061002-A	2.3	FT-FY21-022021-061002-B	<1
Imagine Hope PCS [Tolson]	WS-061-003	Combo Fountain	1	In classroom 111		Right	WF-022021-061003-03	5/12/2021	FT-FY21-022021-061003-A	<1	FT-FY21-022021-061003-B	<1
Imagine Hope PCS [Tolson]	WS-061-004	Combo Faucet	1	In classroom 106		Left	WF-022021-061004-03	N/A	FT-FY21-022021-061004-A	Non-Op	FT-FY21-022021-061004-B	Non-Op
Imagine Hope PCS [Tolson]	WS-061-005	Combo Fountain	1	In classroom 106		Right	WF-022021-061005-03	N/A	FT-FY21-022021-061005-A	Non-Op	FT-FY21-022021-061005-B	Non-Op
Imagine Hope PCS [Tolson]	WS-061-006	Combo Faucet	1	In classroom 105		Left	WF-022021-061006-03	5/12/2021	FT-FY21-022021-061006-A	1.3	FT-FY21-022021-061006-B	<1
Imagine Hope PCS [Tolson]	WS-061-007	Combo Fountain	1	In classroom 105		Right	WF-022021-061007-03	5/12/2021	FT-FY21-022021-061007-A	<1	FT-FY21-022021-061007-B	<1
Imagine Hope PCS [Tolson]	WS-061-008	Combo Faucet	1	In classroom 112		Left	WF-022021-061008-03	5/12/2021	FT-FY21-022021-061008-A	<1	FT-FY21-022021-061008-B	<1
Imagine Hope PCS [Tolson]	WS-061-009	Combo Fountain	1	In classroom 112		Right	WF-022021-061009-03	5/12/2021	FT-FY21-022021-061009-A	<1	FT-FY21-022021-061009-B	<1
Imagine Hope PCS [Tolson]	WS-061-010	Combo Faucet	1	In classroom 104		Left	WF-022021-061010-03	5/12/2021	FT-FY21-022021-061010-A	1.9	FT-FY21-022021-061010-B	<1
Imagine Hope PCS [Tolson]	WS-061-011	Combo Fountain	1	In classroom 104		Right	WF-022021-061011-03	5/12/2021	FT-FY21-022021-061011-A	<1	FT-FY21-022021-061011-B	<1
Imagine Hope PCS [Tolson]	WS-061-012	Combo Faucet	1	In classroom 103		Left	WF-022021-061012-03	5/12/2021	FT-FY21-022021-061012-A	2.0	FT-FY21-022021-061012-B	<1
Imagine Hope PCS [Tolson]	WS-061-013	Combo Fountain	1	In classroom 103		Right	WF-022021-061013-03	N/A	FT-FY21-022021-061013-A	Non-Op	FT-FY21-022021-061013-B	Non-Op
Imagine Hope PCS [Tolson]	WS-061-014	Combo Faucet	1	In classroom 114		Left	WF-022021-061014-03	5/12/2021	FT-FY21-022021-061014-A	1.5	FT-FY21-022021-061014-B	<1
Imagine Hope PCS [Tolson]	WS-061-015	Combo Fountain	1	In classroom 114		Right	WF-022021-061015-03	5/12/2021	FT-FY21-022021-061015-A	<1	FT-FY21-022021-061015-B	<1
Imagine Hope PCS [Tolson]	WS-061-016	Combo Faucet	1	In classroom 113		Left	WF-022021-061016-03	5/12/2021	FT-FY21-022021-061016-A	3.4	FT-FY21-022021-061016-B	<1
Imagine Hope PCS [Tolson]	WS-061-017	Combo Fountain	1	In classroom 113		Right	WF-022021-061017-03	5/12/2021	FT-FY21-022021-061017-A	<1	FT-FY21-022021-061017-B	<1
Imagine Hope PCS [Tolson]	WS-061-018	Cooler	1	In hallway adjacent to room 113	High	Left	WF-022021-061018-03	N/A	FT-FY21-022021-061018-A	Non-Op	FT-FY21-022021-061018-B	Non-Op
Imagine Hope PCS [Tolson]	WS-061-019	Cooler	1	In hallway adjacent to room 113	Low	Right	WF-022021-061019-03	N/A	FT-FY21-022021-061019-A	Non-Op	FT-FY21-022021-061019-B	Non-Op
Imagine Hope PCS [Tolson]	WS-061-020	Cooler	2	In hallway adjacent to room 214	High	Left	WF-022021-061020-03	N/A	FT-FY21-022021-061020-A	Non-Op	FT-FY21-022021-061020-B	Non-Op
Imagine Hope PCS [Tolson]	WS-061-021	Cooler	2	In hallway adjacent to room 214	Low	Right	WF-022021-061021-03	N/A	FT-FY21-022021-061021-A	Non-Op	FT-FY21-022021-061021-B	Non-Op
Imagine Hope PCS [Tolson]	WS-061-022	Health Suite	1	In nurse suite			WF-022021-061022-03	5/12/2021	FT-FY21-022021-061022-A	<1	FT-FY21-022021-061022-B	<1